

# A.P.POWER GENERATION CORPORATION LIMITED

## ABSTRACT

VTPS-I- Dismantling, Erection & Commissioning of certain works in boiler & turbine areas of units.1&2, VTPS during AOH/COH in 2006-07 – Approval – Accorded - Reg.

G.O.O. No: 172 /(Generation. I)/2006

Dt.26-06-2006

Read the following:-

Note Dt.7.03.2006 from CE/Generation-I/VS/Hyderabad  
Minutes dt.29.03.2006 of 56<sup>th</sup> Board meeting of the company held on 25.03.2006

### ORDER:

CE/Generation-I has stated that the unit-2, VTPS was commissioned during the year 1980 and since then the unit is in continuous service. CE/Generation-I has also stated that as the unit has served its life of more than 25 years, the unit is programmed for COH during 2006-07 to take up the modification of PA opening from 50deg to 72deg which will take around 60 days. It is proposed to take up the opportunity for carrying out the following works and the required material for said works were already ordered.

- (a) Replacement of LTSH Coil assembly for unit-2
- (b) Replacement re-heater coil assemblies for unit-2
- (c) Modification of pent house bottom plate for unit-2
- (d) Replacement of ID Fan outlet dampers for unit-2
- (e) Addl works in APH Modification for unit-2
- (f) Erection & commissioning of hangers and supports for critical piping of boiler& turbine areas in unit.1 in AOH and unit.2 in COH

The BOARD during its 56<sup>th</sup> meeting held on 25.03.2006 considered the proposal for carrying out the above works through M/s. BHEL/ Secunderabad and directed Chief Engineer (Generation-I) to arrange negotiations with the company at the level of Director (Thermal), Director(Commercial) and Director(Finance). Accordingly, negotiations were held with the company on 12.4.2006

After careful consideration, the APGENCO directs the Chief Engineer (Generation-I) to place orders for carrying out the above works in boiler & turbine areas of units.1&2 during AOH/COH in the year 2006-07 on M/s. BHEL at the negotiated prices of Rs.445Lakhs (Rupees Four Hundred and Forty five Lakhs only) with the following terms and conditions.

a) Prices	: Firm
(i) Replacement of LTSH Coil assemblies in unit-2	: Rs 95,00,000.00
(ii) Replacement of Re-heater coil assemblies in unit-2	: Rs 81,00,000.00
(iii) Modification of pent house bottom plate in unit.2	: Rs. 52,00,000.00
(iv) Replacement of ID Fan outlet dampers in unit.2	: Rs. 7,00,000.00
(v) Addl works in APH modification in unit.2	: Rs. 91,00,000.00
(vi) Erection & Commissioning of hangers & supports for critical piping of boiler & turbine areas of units.1&2	: Rs.1,19,00,000.00
Total	: <b>Rs.4,45,00,000.00</b>
(Rupees Four Crores Forty five Lakhs only)	

(Contd..2)

::2::

- b) Service tax including education cess : Extra at the rate prevailing at the time of execution of work. Present rate is 12.24% (Including education cess)
- c) Storage insurance : Extra
- d) Statutory variation of taxes : To APGENCO account
- e) Guarantee : 6 months from the date of completion of work for any defective workmanship
- f) Payment terms :  
10% contract value along with service tax and education cess as interest free advance, 30% contract value along with service tax and education cess within 30 days on completion of dismantling activity & receipt of invoice, 50% of contract value along with service tax and education cess within 30 days on completion of re-assembly works & receipt of invoice and balance 10% of contract value along with service tax & education cess within 30 days on completion of guarantee period
- g) Mobilization period : 15 days
- h) Completion period : 75 days

This order is issued with the concurrence of Director (Finance).


(BY ORDER AND IN THE NAME OF APGENCO)

AJAY JAIN  
MANAGING DIRECTOR

To  
The Chief Engineer (Generation-I),  
Vidyut Soudha, Hyderabad.

Copy communicated to  
Chief Engineer/O&M/VTPS/Ibrahimpattam - 521 456  
PS to MD/APGENCO/VS/ Hyderabad  
PS to CGM (Adm) /APGENCO/VS / Hyderabad(3 copies)

// T.C.F.B.O //

  
Asst. Divisional Engineer 26/06/06