

APGENCO - Thermal stations operational performance

Station		Dr NTTPS I	Dr NTTPS II	Dr NTTPS III	Dr NTTPS IV	RTPP I	RTPP II	RTPP III	Total
Capacity (in MW)		2 X 210	2 X 210	2 X 210	1 X 500	2 X 210	2 X 210	1 X 210	
Generation (MU)	2009-10	3462.74	3079.38	3164.4	1020.66	3269.90	3106.68		17103.8
	2010-11	3183.17	3349.85	2125.2	3751.45	2934.03	3116.61	204.68	18665.0
	2011-12	3285.84	3437.43	3314.82	4121.19	3254.26	3315.00	1506.51	22235.1
	2012-13	2964.64	3427.82	3274	3744.05	2918.97	3281.09	1492.55	21103.1
	2013-14	2745.68	3165.98	3140.74	3781.02	2624.35	3009.59	1422.75	19890.1
Aux con (%)	2009-10	8.71	8.9	8.94	4.39	10.17	8.59		8.88
	2010-11	9.09	9.14	9.39	4.42	10.70	8.69	9.50	8.37
	2011-12	9.09	9.05	9.29	4.78	10.13	8.49	9.48	8.4
	2012-13	9.53	9.37	9.48	4.8	10.42	8.66	9.76	8.66
	2013-14	9.7	9.51	9.46	4.91	11.12	8.96	10.31	8.84
PLF (%)	2009-10	94.12	83.7	86.01	85.8	88.88	84.44		87.36
	2010-11	86.52	91.05	57.76	85.65	79.75	84.71	64.44	69.73
	2011-12	89.06	93.17	89.85	93.83	88.21	89.85	81.67	90.08
	2012-13	80.58	93.17	88.99	85.48	79.34	89.18	81.13	85.73
	2013-14	74.63	86.05	85.36	86.32	71.33	81.80	77.34	80.8